

Details of Non Compliance: for Licence W0232-01



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy \(W0232-01\)](#) >> [All Non Compliances](#) >> View Non Compliance NC010791

Non Compliance NC010791 for Dublin Waste to Energy (W0232-01)

Non Compliance Type:

Miscellaneous

Non Compliance Condition:

3.18.6

Notification Date:

06/03/2018

Date of Non-Compliance (1st Date if relates to a period):

01/03/2018

Last Date of Non-Compliance in calendar month (if a period)

02/03/2018

Description:

On 01/03/2017 and 02/03/2017 the licensee failed to automatically switch on the auxiliary burner in order to maintain a temperature of 850°C or greater while waste was in the combustion chamber. This is a non-compliance with condition 3.18.6 of the licence which states that "Each line of the incineration plant shall be equipped with at least one auxiliary burner. The burner shall be switched on automatically when the temperature of the combustion gases after the last injection of combustion air falls below 850°C. The auxiliary burner shall also be used during plant start-up and shut-down operations in order to ensure the temperature of 850°C is maintained at all times during the operations and as long as unburned waste is in the combustion chamber".

Incident

Number	Nature	Created Date
INCI013973	Other	02/03/2018

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | edenenforcementsupport@epa.ie