

View of an Incident INCI013960



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy \(W0232-01\)](#) >> [All Incidents](#) >> View Incident INCI013960

Incident INCI013960 for Dublin Waste to Energy Licence (W0232-01)

Notification No: INCI013960

Submitted: 01/03/2018

Licensee Details

First name

Mark

Surname

Heffernan

Address 1

Pidgeon House Road

Address 2

Ringsend

Town

County

Telephone

0863860942

Alternate phone

Incident Details

Description of Incident

During testing and Commissioning of Lines 1 and 2, the furnace temperature of line 2 dropped below 850oC between 02:43hrs and 06:47hrs on 01 March 2018.(244 mins)

This event was during the planned outage period. Line 1 was offline at the time.

There was a power outage in the adjacent facility (Dublin Bay Power) which may have caused a disturbance to facility operations, this is currently being investigated. Close out report to follow.

Incident Category

Category 1

Approximate start of incident?

01/03/2018 02:43

First noticed

01/03/2018 02:44

Still ongoing?

No

Finish date/time

01/03/2018 06:47

New or recurring Incident?

New

Incident nature

Other

Other Incident nature (as submitted)

During testing and commissioning of Lines 1 and 2, the furnace temperature of line 2 dropped below 850oC between 02:43hrs and 06:47hrs on 01 March 2018.(244 mins)

This event was during the planned outage period. Line 1 was offline at the time.

Impact of Incident on Environment

Daily CEMS report to follow
 Facility Management are in current discussions with EIRGRID and contractor ABB
 Close out report detailing the root cause of the event and the corrective actions will require additional time and will be uploaded to EDEN by April 6th 2018.

Uncontrolled release to receptors

No uncontrolled release

Details of any vulnerable receptors

N/A

Likely Cause

Power failure

Incident Location

Discharge Point

No

Incident location description

During testing and Commissioning of Lines 1 and 2, the furnace temperature of line 2 dropped below 850oC between 02:43hrs and 06:47hrs on 01 March 2018.(244 mins) This event was during the planned outage period. Line 1 was offline at the time.

Communication to Date

EPA notified by phone?

Yes

Date/Time

01/03/2018 08:20

EPA Contact Name

EPA afterhours contact number

EPA Contact Details

053 9160600

Local authorities notified?

No

Inland Fisheries notified?

No

Other agencies notified?

No

Additional Incident Details

Activity in progress at time of incident

During testing and Commissioning of Lines 1 and 2, the furnace temperature of line 2 dropped below 850oC between 02:43hrs and 06:47hrs on 01 March 2018.(244 mins)
 This event was during the planned outage period. Line 1 was offline at the time.

Corrective Actions taken

Action	Date & Time
Investigation ongoing	07/03/2018 12:00

Preventative Actions to be taken

Action	Target Date
Investigation ongoing as to the cause of this event	07/03/2018

Likelihood of Recurrence

Low

Uploaded files

File Name
Snapshot-INC1013960.pdf
01 March 2018 Daily CEMS Report.pdf
INC1013960 Close out Report 12 March 2018.pdf
Incident 13788 and 13960 Cover letter 09042018.pdf

[JRE-HZI-50072837_1.0_Dublin_WTE_Power_Loss_on_02.03.2018.pdf](#)

Other relevant information

Close out report and Daily CEMS report to follow

Notes

No Notes specified.

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | edenenforcementsupport@epa.ie