

View of an Incident INCI013973



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy \(W0232-01\)](#) >> [All Incidents](#) >> View Incident INCI013973

Incident INCI013973 for Dublin Waste to Energy Licence (W0232-01)

Notification No: INCI013973

Submitted: 02/03/2018

Licensee Details

First name

Mark

Surname

Heffernan

Address 1

Pidgeon House Road

Address 2

Ringsend

Town

County

Telephone

0863860942

Alternate phone

Incident Details

Description of Incident

During testing and commissioning of lines 1 and 2, and during the plants first outage period, the furnace temperature of line 2 dropped below 850oC on 02 March 2018 at 01:40hrs. Line 1 was off line due to outage at the time. During this period storm Emma had caused power outages in the vicinity of the Plant which caused the plant to trip at this time.

Incident Category

Category 1

Approximate start of incident?

02/03/2018 01:40

First noticed

02/03/2018 01:41

Still ongoing?

No

Finish date/time

02/03/2018 19:11

New or recurring Incident?

New

Incident nature

Other

Other Incident nature (as submitted)

During testing and commissioning of lines 1 and 2, and during the plants first outage period, the furnace temperature of line 2 dropped below 850oC on 02 March 2018 at 01:40hrs. Line 1 was off line due to outage at the time. During this period storm Emma had caused power outages in the vicinity of the Plant which caused the plant to trip at this time.

Impact of Incident on Environment

Close out report to follow

Facility Management are in current discussions with EIRGRID and contractor ABB

Close out report detailing the root cause of the event and the corrective actions will require additional time and will be uploaded to EDEN by April 6th 2018.

Uncontrolled release to receptors

No uncontrolled release

Details of any vulnerable receptors

n/a

Likely Cause

Adverse Weather

Incident Location**Discharge Point**

No

Incident location description

During testing and commissioning of lines 1 and 2, and during the plants first outage period, the furnace temperature of line 2 dropped below 850oC on 02 March 2018 at 01:40hrs. Line 1 was off line due to outage at the time. During this period storm Emma had caused power outages in the vicinity of the Plant which caused the plant to trip at this time.

Communication to Date**EPA notified by phone?**

Yes

Date/Time

02/03/2018 08:40

EPA Contact Name

After hours phone number

EPA Contact Details

053 916 0600

Local authorities notified?

No

Inland Fisheries notified?

No

Other agencies notified?

No

Additional Incident Details**Activity in progress at time of incident**

During testing and commissioning of lines 1 and 2, and during the plants first outage period, the furnace temperature of line 2 dropped below 850oC on 02 March 2018 at 01:40hrs.

Line 1 was off line due to outage at the time.

During this period storm Emma had caused power outages in the vicinity of the Plant which caused the plant to trip at this time.

Corrective Actions taken

Action	Date & Time
Investigation ongoing	07/03/2018 12:00

Preventative Actions to be taken

Action	Target Date
Investigation ongoing	07/03/2018

Likelihood of Recurrence

Low

Uploaded files

File Name
Snapshot-INCI013973.pdf
02 March 2018 Daily CEMS Report.pdf
HZI-COV-06589.pdf
INCI013973 Close out Report 12 March 2018.pdf

[JRE-HZI-50072837_0.0_Dublin_WTE_Power_Loss_on_02.03.2018.pdf](#)

[Incident_13973_02_March_2018_Cover_letter_09042018.pdf](#)

[JRE-HZI-50072837_1.0_Dublin_WTE_Power_Loss_on_02.03.2018.pdf](#)

Other relevant information

Restart of plant time to follow
close out report to follow

Notes

No Notes specified.

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | edenenforcementsupport@epa.ie