

Incident INCI012973 for Dublin Waste to Energy Licence (W0232-01)

Notification No: INCI012973

Submitted: 04/10/2017 17:13

Licensee Details

First Name:

Mark

Surname:

Heffernan

Address 1:

Pidgeon House Road

Address 2:

Ringsend

Town:**County:****Phone:**

0863860942

Alternate phone:

Details

Description of Incident:

During Testing and Commissioning of Lines 1 and 2 there was a breach of ELV's for SO2 on Line 1 as follows:

12:00hrs - 509.55

12:30hrs - 431.46

13:00hrs - 236.18

13:30hrs - 58.58

14:30hrs - 67.83

Incident Category:

Category 1

Approximate Start of Incident:

04/10/2017 12:00

First Noticed:

04/10/2017 12:05

Still Ongoing:

No

End Date:

04/10/2017 14:00

New or Recurring Incident:

New

Incident Nature:

Breach of ELV

Impact of Incident on Environment:

During Testing and Commissioning of Lines 1 and 2 there was a breach of ELV's for SO2 on Line 1 as follows:

12:00hrs - 509.55

12:30hrs - 431.46

13:00hrs - 236.18

13:30hrs - 58.58

14:30hrs - 67.83

All APC's were in operation during the incident. Air dispersion model has been carried out. Report to follow.

CEMS daily report to follow.

Uncontrolled Release to Receptors:

Air

Details of any Vulnerable Receptors:

N/A

Likely Cause:

Other (add details)

Investigation underway

Emission Parameters

Parameter	Value	Date	Method
Sulphur dioxide (mg/m3)	509.55000000	04/10/2017 12:00	Continuous
Sulphur dioxide (mg/m3)	431.46000000	04/10/2017 12:30	Continuous

Incident Location

Discharge Point:

Yes

W0232-A2-1 & A2-2

Communication

Informed by Telephone: Yes

Informed Date: 04/10/2017 16:34

Informed Staff Member: Pat Byrne

Informed Contact Details: 01 2680100

Other Communications:

Additional Details

Activity in Process at time of incident:

During Testing and Commissioning of Lines 1 and 2 there was a breach of ELV's for SO2 on Line 1 as follows:

12:00hrs - 509.55

12:30hrs - 431.46

13:00hrs - 236.18

13:30hrs - 58.58

14:30hrs - 67.83

Corrective Actions Taken:

Action	Name	Date
Report to follow		11/10/2017 11:00

Preventive Actions to be Taken:

Action	Target Date
Report to follow	11/10/2017 00:00

Likelihood of Recurrence: Low

Other Relevant Information

Investigation underway. Report to follow