

Details of Non Compliance: for Licence W0232-01



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy \(W0232-01\)](#) >> [All Non Compliances](#) >> View Non Compliance NC011440

Non Compliance NC011440 for Dublin Waste to Energy (W0232-01)

Non Compliance Type:

Miscellaneous

Non Compliance Condition:

3.18.5

Notification Date:

13/07/2018

Date of Non-Compliance (1st Date if relates to a period):

29/06/2018

Last Date of Non-Compliance in calendar month (if a period)**Description:**

On 29/06/2018 the licensee failed to operate the incineration plant in such a way that after the last injection of combustion air, the gas resulting from the process was raised, in a controlled and homogeneous fashion, for a duration of two seconds to a temperature of 850°C or greater. This is a non-compliance with condition 3.18.5 of the industrial emissions licence Reg. No. W0232-01 which states that "even under the most unfavourable of conditions, the incineration plant shall be operated in such a way that, after the last injection of combustion air, the gas resulting from the process is raised, in a controlled and homogeneous fashion, for a duration of two seconds to a temperature of 850°C".

Incident

Number	Nature	Created Date
INCI014694	Other	29/06/2018

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | edenenforcementsupport@epa.ie