

## Details of Non Compliance: for Licence W0232-01



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy\\_\(W0232-01\)](#) >> [All Non Compliances](#) >> View Non Compliance NC012620

### Non Compliance NC012620 for Dublin Waste to Energy (W0232-01)

**Non Compliance Type:**

ELV exceedance

**Non Compliance Condition:**

5.1

**Notification Date:**

11/09/2018

**Date of Non-Compliance (1st Date if relates to a period):**

10/09/2018

**Last Date of Non-Compliance in calendar month (if a period)****Description:**

The licensee's analysis report of samples taken at emission point Ref. No. SW-1 recorded breaches of the hourly specified emission limit value of 0.5mg/l for Total Residual Chlorine as set out in Schedule B.2 Emission Limits to Water on 10/09/2018 (0.53 mg/l). This is in breach of condition 5.1 of the industrial emissions licence Reg. No. W0232-01 which states that "No specified emission from the facility shall exceed the emission limit values set out in Schedule B: Emission Limits, of this licence. There shall be no other emissions of environmental significance".

**Incident**

Number	Nature	Created Date
<a href="#">INCI015126</a>	Breach of ELV	11/09/2018

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | [edenenforcementsupport@epa.ie](mailto:edenenforcementsupport@epa.ie)