

## Details of Non Compliance: for Licence W0232-01



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy\\_\(W0232-01\)](#) >> [All Non Compliances](#) >> View Non Compliance NC012619

### Non Compliance NC012619 for Dublin Waste to Energy (W0232-01)

**Non Compliance Type:**

Miscellaneous

**Non Compliance Condition:**

3.18.5

**Notification Date:**

19/09/2018

**Date of Non-Compliance (1st Date if relates to a period):**

18/09/2018

**Last Date of Non-Compliance in calendar month (if a period)**

**Description:**

On 18/09/2018 the licensee failed to operate the incineration plant line 2 for 24 minutes in such a way that after the last injection of combustion air, the gas resulting from the process was raised, in a controlled and homogeneous fashion, for a duration of two seconds to a temperature of 850°C or greater. This is a non-compliance with condition 3.18.5 of the industrial emissions licence Reg. No. W0232-01 which states that "even under the most unfavourable of conditions, the incineration plant shall be operated in such a way that, after the last injection of combustion air, the gas resulting from the process is raised, in a controlled and homogeneous fashion, for a duration of two seconds to a temperature of 850°C".

**Incident**

Number	Nature	Created Date
<a href="#">INCI015170</a>	Other	19/09/2018

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | [edenenforcementsupport@epa.ie](mailto:edenenforcementsupport@epa.ie)