

Incident INCI015876 for Dublin Waste to Energy Licence (W0232-01)

Notification No: INCI015876

Submitted: 25/01/2019 09:24

Licensee Details

First Name:

Mark

Surname:

Heffernan

Address 1:

Pidgeon House Road

Address 2:

Ringsend

Town:

Poolbeg

County:

Phone:

0863860942

Alternate phone:

Details

Description of Incident:

During Testing and Commissioning of Lines 1 and 2, The furnace temperature on Line 1 dropped below 850oC for a total of 29 mins on 24 January 2019. From 08:22hrs to 08:39hrs (17 mins) and 08:50hrs to 09:02hrs.(12 mins)

Incident Category:

Category 1

Approximate Start of Incident:

24/01/2019 08:22

First Noticed:

24/01/2019 08:23

Still Ongoing:

No

End Date:

24/01/2019 09:02

New or Recurring Incident:

New

Incident Nature:

Other

Impact of Incident on Environment:

None. All air pollution control systems were operational. Daily CEMS report compliant.

Uncontrolled Release to Receptors:

No
uncontrolled
release

Details of any Vulnerable Receptors:

None

Likely Cause:

Plant or equipment breakdown (Not at WWTP)

Incident Location

Discharge Point:

No

During Testing and Commissioning of Lines 1 and 2, The furnace temperature on Line 1 dropped below 850oC for a total of 29 mins on 24 January 2019. From 08:22hrs to 08:39hrs (17 mins) and 08:50hrs to 09:02hrs.(12 mins)

Communication

Informed by Telephone: Yes

Informed Date: 24/01/2019 11:58

Informed Staff Member: Simon Buckley

Informed Contact Details: 01 2680100

Other Communications:

Additional Details

Activity in Process at time of incident:

Normal activities

Corrective Actions Taken:

Action	Name	Date
Close out report to follow		31/01/2019 14:00

Preventive Actions to be Taken:

Action	Target Date
Close out report to follow	31/01/2019 00:00

Likelihood of Recurrence: Low

Other Revelant Information