Details of Non Compliance: for Licence W0232-01



Eden >> All Licences >> Dublin Waste to Energy (W0232-01) >> All Non Compliances >> View Non Compliance NC013299

Non Compliance NC013299 for Dublin Waste to Energy (W0232-01)

Non Compliance Type:

Miscellaneous

Non Compliance Condition:

3.18.5

Notification Date:

24/01/2019

Date of Non-Compliance (1st Date if relates to a period):

24/01/2019

Last Date of Non-Compliance in calendar month (if a period)

Description:

On 24/01/2019 the licensee failed to operate the incineration plant in such a way that after the last injection of combustion air, the gas resulting from the process was raised, in a controlled and homogeneous fashion, for a duration of two seconds to a temperature of 850°C or greater. This is a non-compliance with condition 3.18.5 of the industrial emissions licence Reg. No. W0232-01 which states that "even under the most unfavourable of conditions, the incineration plant shall be operated in such a way that, after the last injection of combustion air, the gas resulting from the process is raised, in a controlled and homogeneous fashion, for a duration of two seconds to a temperature of 850°C ".

Incident

Number	Nature	Created Date
<u>INCI015876</u>	Other	25/01/2019

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | edenenforcementsupport@epa.ie