Details of Non Compliance: for Licence W0232-01

Eden >> All Licences >> Dublin Waste to Energy (W0232-01) >> All Non Compliances >> View Non Compliance NC013495

Non Compliance NC013495 for Dublin Waste to Energy (W0232-01)

Non Compliance Type:

ELV exceedance

Non Compliance Condition:

5.1

Notification Date:

22/02/2019

Date of Non-Compliance (1st Date if relates to a period):

22/02/2019

Last Date of Non-Compliance in calendar month (if a period)

Description:

On 22/02/2019, two half hourly concentrations of sulphur dioxide (SO2), recorded at Emission Point Ref. No. A2-2, were in breach of the emission limit value (ELV) (211.31mg/m3 and 207.08mg/m3 versus the half hourly ELV of 200mg/m3) as set out in Schedule B.1 of the Industrial Emissions (IE) Licence Register No. W0232-01. This is a non-compliance with Condition 5.1 of the IE licence which states "No specified emission from the facility shall exceed the emission limit values set out in Schedule B: Emission Limits, of this licence. There shall be no other emissions of environmental significance".

Incident

Number	Nature	Created Date
INCI016051	Breach of ELV	25/02/2019

EDEN - EPA, Johnstown Castle, Co. Wexford - Phone: +353 (0)53 9160600 | edenenforcementsupport@epa.ie