

Details of Non Compliance: for Licence W0232-01



[Eden](#) >> [All Licences](#) >> [Dublin Waste to Energy \(W0232-01\)](#) >> [All Non Compliances](#) >> View Non Compliance NC013723

Non Compliance NC013723 for Dublin Waste to Energy (W0232-01)

Non Compliance Type:

ELV exceedance

Non Compliance Condition:

5.1

Notification Date:

09/04/2019

Date of Non-Compliance (1st Date if relates to a period):

19/02/2019

Last Date of Non-Compliance in calendar month (if a period)

Description:

The Agency's air emissions monitoring report, reference number SV16338, dated 09/04/2019, indicated that there was an exceedance of the emission limit value (ELV) for Volumetric flow, as stated in Schedule B Emission Limits licence register number W0232-01, for emissions to air at Emission Point Reference Number A2-1. On 19/02/2019, the result for Volumetric flow was 298070 m3/h versus the ELV of 275000 m3/h. This is a non-compliance with Condition 5.1.