

Incident INCI016051 for Dublin Waste to Energy Licence (W0232-01)

Notification No: INCI016051

Submitted: 25/02/2019 11:27

Licensee Details

First Name:

Mark

Surname:

Heffernan

Address 1:

Pidgeon House Road

Address 2:

Ringsend

Town:

Poolbeg

County:

Phone:

0863860942

Alternate phone:

Details

Description of Incident:

During Testing and Commissioning of Lines 1 and 2, there were 2 half hour ELV breaches for SO2 on line 2 on 22 February 2019 at 19:00hrs and 19:30hrs of 211.31mg/m3 and 207.08mg/m3 respectively.

Incident Category:

Category 1

Approximate Start of Incident:

22/02/2019 19:00

First Noticed:

22/02/2019 19:00

Still Ongoing:

No

End Date:

22/02/2019 19:31

New or Recurring Incident:

New

Incident Nature:

Breach of ELV

Impact of Incident on Environment:

No impact

Uncontrolled Release to Receptors:

Air

Details of any Vulnerable Receptors:

none

Likely Cause:

Variation in Fuel and/or raw materials

Emission Parameters

Parameter	Value	Date	Method
Sulphur dioxide (mg/m3),Sulphur dioxide (mg/m3)	211.3100000000	22/02/2019 19:00	Continuous
Sulphur dioxide (mg/m3)	207.0800000000	22/02/2019 19:30	Continuous

Incident Location

Discharge Point:

Yes

W0232-A2-1 & A2-2

Communication

Informed by Telephone: Yes

Informed Date: 22/02/2019 23:30

Informed Staff Member: After hours Contact Number

Informed Contact Details: 0539160600

Other Communications:

Additional Details

Activity in Process at time of incident:

Normal activities

Corrective Actions Taken:

Action	Name	Date
Review incident		28/02/2019 12:00

Preventive Actions to be Taken:

Action	Target Date
review possible outcomes of any potential RCA's.	28/02/2019 00:00

Likelihood of Recurrence: Low

Other Revelant Information

Close out report to follow with Daily CEMS report for 22 February 2019.