# Incident INCI016224 for Dublin Waste to Energy Licence (W0232-01)

## Notification No: INCI016224

Submitted: 25/03/2019 17:45

**Licensee Details** First Name: Mark Surname: Heffernan Address 1: Pidgeon House Road Address 2: Ringsend Town: Poolbeg County: Phone: 0863860942 Alternate phone: Details **Description of Incident:** Minor fire contained in waste bunker. Fire dealt with in a controlled manner. No interruption to normal plant activities. **Incident Category:** Category 1 **Approximate Start of Incident:** 24/03/2019 15:30 **First Noticed:** 

25/03/2019 15:31

Still Ongoing:

No

End Date: 24/03/2019 16:30

New or Recurring Incident:

New

#### **Incident Nature:**

Fire

### Impact of Incident on Environment:

None

#### **Uncontrolled Relase to Receptors:**

No uncontrolled release

**Details of any Vulnerable Receptors:** 

None

### Likely Cause:

Variation in Fuel and/or raw materials

Incident Location					
Discharge Point:					
No					
Waste bunker					
Communication					
Informed by Telephone: Yes		Informed Date: 25/03/2019 09:39			
Informed Staff Member: (	Dliver Gray				
Informed Contact Details: 012680100					
Other Communications:					
Notified	Contact Details / Telephone	Date			

Dublin City Council	01 222 2222	25/03/2019 09:45

# **Additional Details**

### Activity in Process at time of incident:

Normal Activities

### **Corrective Actions Taken:**

Action	Name	Date
ERP activated for fire response. Fire dealt with in a controlled manner using site fire protection equipment in parallel with supervision from Dublin City Fire Brigade. No interruption to normal plant activities.		24/03/2019 15:30

### **Preventive Actions to be Taken:**

Action	Target Date
No additional actions to be taken as all plant fire protection systems operated as per design in a controlled manner.	25/03/2019 00:00

Likelyhood of Recurrence: Low

**Other Revelant Information**